



## SIDEWALK REGULATIONS

No person shall remove, reconstruct or install a sidewalk unless such person has obtained a Sidewalk Construction Permit from the City. Sidewalks repaired, replaced or constructed must meet the following construction standards:

1. Portland cement shall be the only cement used in the construction and repair of sidewalks.
2. Sidewalks shall be of one-course construction.
3. Concrete may be placed directly on compact and well-drained soil. Where soil is not well drained, a three (3) inch sub-base of compact, clean, coarse gravel, sand, or cinders shall be laid. The adequacy of the soil drainage is to be determined by the City.
4. The sidewalk bed shall be so graded that the constructed sidewalk will be at established grade.
5. Length, Width and Depth. Length, width and depth requirements are as follows:
  - A. Residential sidewalks shall be at least 4 feet wide and 4 inches thick, with each section no more than six feet in length.
  - B. Business District sidewalks shall extend from the property line to the curb. Each section shall be 4 inches thick and no more than 6 feet in length.
  - C. Driveway areas shall be not less than 6 inches in thickness.
6. Residential sidewalks shall be located with the inner edge (edge nearest the abutting private property) one foot from the property line, unless the Council establishes a different distance due to special circumstances.
7. Curb tops shall be level with the centerline of the street, which shall be the established grade.
8. The street edge of a sidewalk shall be at an elevation even with the curb at the curb or not less than one-half inch above the curb for each foot between the curb and the sidewalk.

(See other side for more information)

9. 10. All sidewalks shall slope one-quarter inch per foot toward the curb.
10. All sidewalks shall be finished with a "broom" or "wood float" finish.
11. There shall be not less than two (2) curb cuts or ramps per lineal block which shall be located on or near the crosswalks at intersections. Each curb cut or ramp shall be at least thirty (30) inches wide, shall be sloped at not greater than one inch of rise per twelve (12) inches lineal distance, except that a slope no greater than one inch of rise per eight (8) inches lineal distance may be used where necessary, shall have a nonskid surface, and shall otherwise be so constructed as to allow reasonable access to the crosswalk for physically handicapped persons using the sidewalk.